

RESOLUTION NO. 90-136

=====

A RESOLUTION OF THE LODI CITY COUNCIL
AWARDING THE BID FOR THE PURCHASE OF 21 PAD-MOUNT TRANSFORMERS

=====

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened on August 7, 1990 at 11:00 a.m. for the bid for the purchase of 21 pad-mount transformers, described in the specifications therefor approved by the City Council on June 6, 1990; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Exhibit A attached hereto; and

WHEREAS, the City Manager recommends that award of the bid for 21 pad-mount transformers, be made to the bidders whose proposals and equipment met all specifications, and yielded the lowest overall life-cycle costs, as follows:

Westinghouse Utilities, Concord	7 Ea 50 KVA Single-Phase	\$ 9,817.50
	8 Ea 100 KVA Single-Phase	14,076.00
	1 Ea 150 KVA Three-Phase	4,823.75
	Total	\$28,717.25
Maydwell & Hartzell, Brisbane	1 Ea 112.5KVA Three-Phase	\$ 3,908.94
Pauwels Transformers, Washington, Missouri	2 Ea 225 KVA Three-Phase	\$12,138.00
	1 Ea 300 KVA Three-Phase	6,926.44
	1 Ea 750 KVA Three-Phase	10,090.56
	Total	\$29,155.00
	GRAND TOTAL	\$61,781.19

NOW, THEREFORE, BE IT RESOLVED by the Lodi City Council that award of bid for 21 pad-mount transformers be and the same is hereby awarded as shown above in the amount of \$61,781.19.

Dated: September 5, 1990

=====

I hereby certify that Resolution No. 90-136 was passed and adopted by the City Council of the City of Lodi in a regular meeting held September 5, 1990 by the following vote:

Ayes: Council Members - Olson, Pinkerton, Reid and Snider (Mayor)

Noes: Council Members - None

Absent: Council Members - Hinchman

Alice M. Reimche
Alice M. Reimche
City Clerk

90-136

RES90136/TXTA.02J

SUMMARY
BIDS RECEIVED*/LIFE CYCLE COSTS
PADMOUNTED TRANSFORMERS
BIDS OPENED AUGUST 7, 1990

TRANSFORMER DESCRIPTION	WESTINGHOUSE CONCORD	COOPER POWER BURLINGAME	ERMCO TENNESSEE	WEST. STATES PORTLAND	MAYO.&HARTZ. BRISBANE	PAUWELS MISSOURI
			(1)	(2)		
<u>SINGLE-PHASE PADMOUNTED:</u>						
7 EA 50KVA, 240/120V	\$ 9,817.50/ <u>\$17,755.50</u>	\$ 8,813.44/ \$19,383.44	\$ 8,627.50/ \$19,883.50	\$12,026.44/ \$21,406.44	\$10,360.44/ \$20,272.44	NO BID
8 EA 100KVA, 240/120V	\$14,076.00/ \$33,980.00	\$18,232.50/ \$36,952.50	\$15,631.50/ \$36,447.50	\$16,337.00/ \$36,401.00	\$16,847.00/ \$35,935.00	NO BID
<u>THREE-PHASE PADMOUNTED:</u>						
1 EA 112.5KVA, 480/277V	\$4,238.31/ \$7,310.31	\$3,944.00/ \$7,208.00	NO BID	NO BID	\$3,908.94/ <u>\$6,726.94</u>	\$4,023.69/ <u>\$7,223.69</u>
1 EA 150KVA, 408/277V	\$4,823.75/ <u>\$8,381.75</u>	\$4,210.69/ \$8,868.69	NO BID	NO BID	\$4,363.69/ \$8,605.69	\$4,581.50/ <u>\$8,451.50</u>
2 EA 225KVA, 480/277V	\$12,057.25/ \$21,981.25	\$10,877.88/ \$22,429.88	NO BID	NO BID	\$ 9,817.50/ \$21,649.50	\$12,138.00/ <u>\$21,554.00</u>
1 EA 300KVA, 480/277V	\$ 6,093.43/ \$13,173.43	\$ 5,763.00/ \$13,461.00	NO BID	NO BID	\$ 6,189.06/ \$13,443.06	\$ 6,926.44/ <u>\$13,130.44</u>
EA 750KVA, 480/277V	\$12,495.00/ \$26,439.00	\$12,691.56/ \$27,955.56	NO BID	NO BID	\$12,780.81/ \$25,836.81	\$10,090.56/ <u>\$25,372.56</u>

FOOTNOTES: * BIDS RECEIVED ARE TOTAL BID PRICES FOR EACH SIZE, TAXES INCLUDED, DELIVERED

- (1) ERMCO DISQUALIFIED DUE TO LACK OF SERVICE FACILITIES WITHIN 200 MILES OF LODI;
HEIGHT FOR ITEM 2 EXCEEDS SPECIFIED LIMIT OF 28"
- (2) WESTERN STATES' PROPOSAL FAILED TO MEET SPECIFICATIONS IN THAT APPLIED VOLTAGE TESTS
ARE NOT PERFORMED ON GRD. WYE UNITS; TRANSFORMER HEIGHTS ARE NOT INDICATED;
PRICE QUOTED IS F.O.B. PLANT, FREIGHT ALLOWED (SPECIFICATIONS ARE F.O.B. DELIVERED).

EXHIBIT A

Attachment 1